



\* NOTE \*

1. 원격 제어용 스위치는 속열조 1대당 1개씩 내장됨
2. 구형 즉열조 연결시에는 10번단자 사용하여 실내기 연결함것.
3. 실외기 주전원 배선용량

전압 \ MODEL	RC-V2G7	RC-V5G7	RC-V7.5G7	RC-V10G7
1φ 220V 60Hz	2C-3.5mm <sup>2</sup> VCT			
3φ 220V 60Hz		3C-3.5mm <sup>2</sup> VCT	3C-5.5mm <sup>2</sup> VCT	3C-8.0mm <sup>2</sup> VCT
3φ 380V 60Hz		3C-3.5mm <sup>2</sup> VCT	3C-3.5mm <sup>2</sup> VCT	3C-5.5mm <sup>2</sup> VCT

TELEPHONE BILL (STANDARD CHARGES)		PROJECT NAME 스형 건축원 시스템		TITLE 실제 집선도	
1 ~ 0.1	0.1	MODEL ST-G(3.6,10,15)CM			
4 ~ 1.8	0.2				
16 ~ 6.3	0.4	DATE BY	DESIGNED BY	CHECK BY	APPRO.
63 ~ 200	0.5	DRAWN BY			
200 ~ 400	0.7				
400 ~ 1000	0.8				
Century Corporation		DRAWING NO.		KT3C0043	